




Left Plot w/ Pics


505-341-0109

Pipe ID L5-1	City	Street ALBRIGHT DR 2070 E	Shape	Map #1	Basin
US Manhole L5-1	Section Length 73.031	Year Laid	Material	Section Type	
DS Manhole L5	Inspected Length 251.5	Year Renewed	Depth US 7.5	Depth DS	Joint Leng... Diameter 10
Cleaned		Situation		Reason	
Date 20181126	Clean Date	Weather		Remark	
Start Time 10:49					
Operator MIKE	Customer	Truck 4161	Inspection Dir. Downstream	Info	
Operator Comment	P.O. Number	Present	Flow Control	Camera	




L5-1

Distance: Pos: Val 1 / 2 : % : Gallons:



Code: TIBU 0.0 ft. Observation: Inspection Begins at Upstream MH
Remarks:




Code: CLV 79.1 ft. 9 Observation: Lateral Active
Remarks:



Code: CLV 154.4 ft. 3 Observation: Lateral Active
Remarks:



Code: CLV 158.8 ft. 9 Observation: Lateral Active
Remarks:



Code: TGO 166.7 ft. Observation: General Observation
Remarks: BELL CRACK H2S



Code: TIED 251.5 ft. Observation: nspection Ends at Downstream MH
Remarks:

L5




Scaled Plot

505-341-0109

Pipe ID L5-1	City	Street ALBRIGHT DR 2070 E	Shape	Map #1	Basin
US Manhole L5-1	Section Length 73.031	Year Laid	Material	Section Type	
DS Manhole L5	Inspected Length 251.5	Year Renewed	Depth US 7.5	Depth DS	Joint Leng... Diameter 10

Cleared		Situation		Reason	
Date 20181126	Clean Date	Weather		Remark	
Start Time 10:49					
Operator MIKE	Customer	Truck 4161	Inspection Dir. Downstream	Info	
Operator Comment	P.O. Number	Present	Flow Control	Camera	



* = clock positions adjusted automatically for reverse inspection